



## Firmware for ioLogik E1200 Series (ioLogik E1210/E1210-T) Release Notes

<b>Version:</b> v3.3	<b>Build:</b> Build22072210
<b>Release Date:</b> Aug 03, 2022	

### Applicable Products

ioLogik E1210, ioLogik E1210-T

### Supported Operating Systems

N/A

### New Features

- Adds the default password "moxa".
- Adds a Password and Login Policy.
- Adds the Notification Message function.

### Enhancements

- Adds the DHCP Option 12 "Server Name".

### Bugs Fixed

- Ethernet/IP cannot establish second input only session.
- Ethernet frame padding information leakage (Etherleak).

### Changes

N/A

### Notes

N/A



<b>Version: v3.2</b>	<b>Build: Build20111915</b>
<b>Release Date: Dec 25, 2020</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- Safe Mode supports Ethernet/IP protocol.

### **Enhancements**

N/A

### **Bugs Fixed**

- DHCP mode will not get the Gateway IP.
- The counter value is reset after power failure when booting up.
- The serial number is displayed incorrectly on the web console.
- Ethernet/IP implicit messages are sent to port 2222 by default.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v3.1</b>	<b>Build: Build19110615</b>
<b>Release Date: Nov 25, 2019</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- EtherNet/IP registration on Moxa's licensing website is no longer required.
- Added case insensitive content-length for RESTful API.

### **Enhancements**

N/A

### **Bugs Fixed**

- Fixed inaccurate counter value when using Modbus to start a pulse (E1210/E1212/E1213).
- Fixed opposite on/off pulse width display on web console (E1211/E1212/E1214).
- Fixed that the offset scaling value will reset after changing the Alias name (E1260).
- Fixed self-rebooting when entering URL in the browser for the configuration file.
- Fixed EDS file import connection error.
- Fixed failure when using save counter on power failure and reset counter at the same time (E1210/E1212/E1213).
- Fixed inaccurate counter value when using high frequency (E1210/E1212/E1213).
- Fixed that the trap community name is not included in the export file.
- Fixed that EtherNet/IP cannot use the "Set Attribute Single" service.
- Added an enable RESTful API setting in the configuration file.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v3.0</b>	<b>Build: Build17111512</b>
<b>Release Date: Jan 16, 2018</b>	

### **Applicable Products**

ioLogik E1210-T, ioLogik E1210

### **Supported Operating Systems**

N/A

### **New Features**

- Added OPTIONS method for RESTful API.
- Added quick access URI for RESTful API.

### **Enhancements**

- Added SNMP Trap Community Setting to the web console.
- Added a note on the password settings page that passwords are limited to 16 characters.

### **Bugs Fixed**

- Fixed DHCP lease time did not ask for extension when half of the lease time elapsed.
- Closed IP forwarding function (Port 0).
- Closed UDP Port 161 when SNMP agent is disabled.
- Fixed RESTful API header case-sensitive issue.
- Fixed invalid token issue on login page when using Firefox.

### **Changes**

N/A

### **Notes**

- This version of the firmware only works with ioSearch v2.0 or later versions.
- To prevent system failure, only update the next or the previous released firmware version to prevent from system failure.



<b>Version: v2.5</b>	<b>Build: Build16091211</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- Added the EtherNet/IP protocol.
- Added RESTful API.
- Added new registers for the Modbus/TCP protocol.
- Added new OIDs for the SNMP protocol.
- Modbus, EtherNet/IP, and RESTful services can be disabled (enabled by default).
- Added sending heartbeat to port 9500 of MX-AOPC UA Server after the heartbeat function is enabled.
- Increased password length from 8 to 16 characters.
- Added a function to check special characters to prevent Cross-Site Scripting.
- Passwords are now sent using the POST method instead of the GET method.

### **Enhancements**

N/A

### **Bugs Fixed**

- Fixed file transfer problems when using the Chrome browser (e.g., firmware update, configuration import or export).

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v2.4</b>	<b>Build: Build16053018</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik E1210, ioLogik E1210-T

**Supported Operating Systems**

N/A

**New Features**

- Improved protocol efficiency for the ioLogik 2500 Series.

**Enhancements**

N/A

**Bugs Fixed**

N/A

**Changes**

N/A

**Notes**

N/A



<b>Version: v2.3</b>	<b>Build: Build15031013</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- Supports ioLogik 2500 expansion mode.
- Supports setting an initial value for a counter.

### **Enhancements**

N/A

### **Bugs Fixed**

- Unable to disable the P2P heartbeat interval.
- When the P2P client heartbeat is larger than 256 the time interval is incorrect.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v2.0</b>	<b>Build: Build13041515</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- Supports SNMP protocol.
- Added P2P heartbeat function.

### **Enhancements**

N/A

### **Bugs Fixed**

- The counter storage is deleted when the power fails.

### **Changes**

N/A

### **Notes**

- This version of firmware only works with ioSearch v1.5 or later versions.
- Use the web console when upgrading the firmware from v1.0 to v1.10.





<b>Version: v1.9</b>	<b>Build: Build11112413</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik E1210, ioLogik E1210-T

**Supported Operating Systems**

N/A

**New Features**

N/A

**Enhancements**

- Ensured that the system works properly after unstable power conditions.

**Bugs Fixed**

N/A

**Changes**

N/A

**Notes**

N/A



<b>Version: v1.8</b>	<b>Build: Build11092917</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1210, ioLogik E1210-T

### **Supported Operating Systems**

N/A

### **New Features**

- Added "Locating I/O" function in General Settings.
- Added Modbus address function code=0x08 for "ECHO" function.
- Counter overflow status displayed in Channel Settings can be cleared manually.

### **Enhancements**

- Improved firmware upgrading speed.
- Removed Modbus/TCP ID checking mechanism.

### **Bugs Fixed**

N/A

### **Changes**

N/A

### **Notes**

- This version of the firmware only works with ioSearch v1.5 or later versions.
- Use the web console when upgrading the firmware from v1.0 to v1.9.